



EXISTING DLRCC 3000 DI WATERMAIN

EXISTING DLRCC 1500 uPVC WATERMAIN

1000 WATERMAIN

1000 WATERMAIN

1000 WATERMAIN

- FIRE HYDRANT NOTES:**
1. FIRE HYDRANTS TO BE POSITIONED A MINIMUM OF 6m FROM THE PROPOSED BUILDING FOUNDATIONS.
 2. LOCATIONS OF FIRE HYDRANTS AS PER FIRE CERTIFICATE DRAWINGS.
 3. FIRE HYDRANTS TO BE IN ACCORDANCE WITH THE FIRE OFFICER RECOMMENDATIONS.
 4. ALL FIRE HYDRANTS TO BE LOCATED IN ACCORDANCE WITH TECHNICAL GUIDANCE DOCUMENT B OF BUILDING REGULATIONS, 1997 & TECHNICAL GUIDANCE DOCUMENT B OF BUILDING REGULATIONS, 2006 STATUTORY INSTRUMENT 487 OF 1997.
 5. FINAL VERIFICATION SHOULD BE SOUGHT FROM THE FIRE AUTHORITY FOR AGREED LAYOUT OF ALL HYDRANTS & THE NUMBER OF WATER SUPPLY CONNECTIONS TO THE FIRE WATER RING MAIN.

LEGEND	
	PROPOSED 1500 WATERMAIN UNO
	EXISTING DLRCC WATERMAIN.
	PROPOSED HYDRANT
	PROPOSED SLUICE VALVE
	PROPOSED AIR VALVE
	DENOTES WATERMETER

ALL NEW WATERMANS TO COMPLY WITH WI STANDARDS AND SPECIFICATIONS.

REV	DATE	DESCRIPTION	D	C	A
B	13.02.2019	ISSUED FOR PLANNING	CD	KMG	KMG

PLANNING

COPYRIGHT RESERVED - THIS DRAWING IS NOT TO BE USED FOR A PURPOSE OTHER THAN THAT FOR WHICH IT HAS BEEN ISSUED BY NICHOLAS O'DWYER LTD. NOR IS IT TO BE COPIED OR REPRODUCED IN ANY MANNER WITHOUT WRITTEN CONSENT.



Unit E4, Nutgrove Office Park,
Nutgrove Avenue, Dublin 14
 T +353 1 296 9000
 F +353 1 296 9001
 E dublin@nodwyer.com
 W www.nodwyer.com

CLIENT
DLRCC

PROJECT
BALLYOGAN COURT

TITLE
WATERMAIN LAYOUT

SCALES	DRAWN	CHECKED	APPROVED
1:500 @A1	C Doyle	KMG	KMG
	DATE	DATE	DATE
	16.12.2018	17.01.2018	17.01.2018
DRAWING No.		REV	
30405-PP-006		B	