

0 16-05-2025 Planning Submission rev date STATUS CODES

98-100

80-99 0-20

98-100

90-99

25-70

Typical Cut / Fill Slopes

Gradient

1(V) : 2(H)\*

1(V) : 6(H)

purpose acceptance
P3 - PLANNING PERMISSION S - ISSUED



T: + 353 1 400 4000 | E: info@dbfl.ie | W: www.dbfl.ie

DUBLIN | CORK | GALWAY | WATERFORD

CABINTEELY GREENWAY

TYPICAL CONSTRUCTION DETAILS -SHEET 2

DUN LAOGHAIRE RATHDOWN COUNTY COUNCIL

thor scale
ICJ AS SHOWN

230119-X-0700-Z00-DTM-DR-DBFL-CE-5202 0


FIGURE 2G

975mm POLE X=450mm min 1200mm POLE X=600mm min 1350mm POLE X=700mm min

POLE TO BE SURROUNDED BY

150mm 30N20 CONRETE

TRAFFIC SIGNAL POLE AND BOX INSTALLATION SCALE 1:25



COPYRIGHT OF THIS DRAWING IS RESERVED BY DBFL CONSULTING NO CHANGES OF WHATSOEVER NATURE ARE TO BE MADE TO ANY DETAILS SET OUT OR CONTAINED IN ANY DBFL SPECIFICATIONS OR DRAWINGS UNLESS THE EXPRESS CONSENT HAS BEEN OBTAINED IN ADVANCE, IN

ENGINEERS. NO PART SHALL BE REPRODUCED OR TRANSMITTED WITHOUT

ALL BITUMINOUS MATERIALS SHALL BE LAID & COMPACTED IN ACCORDANCE WITH SPECIFICATION SERIES 700 & 900.

STONE BLINDING WITH 2-6.3mm AGGREGATE SHALL MEET THE

BS SIEVE SIZE (mm)% BY MASS PASSING 98-100 80-99 0-20

CRUSHED STONE TO PERMEABLE PAVING AREAS WITH 4-20mm AGGREGATE SHALL MEET THE FOLLOWING GRADINGS, IN

BS SIEVE SIZE (mm)% BY MASS PASSING 98-100 90-99 25-70

ANY ROADS PROPOSED TO BE USED FOR CONSTRUCTION TRAFFIC ARE TO HAVE INCREASED DEPTH OF SUB-BASE FOR

ALL GEOGRIDS TO BE LAID IN ACCORDANCE WITH

ALL PERMEABLE PAVING SUB-FORMATION TO BE LAID

10. ALL MINIMUM COVER DEPTHS SHOWN TO UTILITIES ARE

11. CONTRACTOR SHALL VERIFY ALL EXISTING SERVICES AND COVER TO SAME PRIOR TO LAYING CAPPING.

2. STREET LIGHTING LOCATIONS SHALL BE AS PER THE STREET LIGHTING LAYOUT AND COLUMN BASES INSTALLED AS PER STREET LIGHTING DESIGNER.

13. CONTRACTOR SHALL PROVE CBR AT TOP OF CAPPING AT 75m CENTRES PRIOR TO PLACING SUB-BASE. CONTRACTOR SHALL PROVE CBR AT TOP OF SUB-BASE AT 75M CENTRES PRIOR TO

Typical Cut / Fill Slopes	
Slope Depth	Gradient
>0.5m	1(V) : 2(H)*
0.15m< D <0.5m	1(V) : 3(H)
<0.15m	1(V) : 6(H)
*May Cut/Fill Slopes to be 1(\lambda) + 2(\Lambda)	

author scale
ICJ AS SHOWN

230119-X-0700-Z00-DTM-DR-DBFL-CE-5203 0

FIGURE 3C

