



Note - The granted Scheme of 2012 was masterplanned to take circa 1.9 ha of Roof areas & impermeable paving areas. Grass pitch surfaces & Multi Purpose Pitches were deemed to self draining. Proposed 2024 Scheme will incorporate circa 1.0 ha from previous/extended roof/impermeable area development with circa 0.4ha new Roof & Green Roof and circa 0.50 ha new permeable area

Key

	Existing surface water
	Proposed surface water
	Existing Foul water
	Proposed surface water
	Existing 100mm dia water main
	Proposed 100mm dia water main
	Proposed Hydrant

Notes
 Existing drainage & water main layouts transcribed from the following planning documents prepared by others. s prepared by others.
 Drawing - 072-171-002-P2- Michael Punch & Partners dated 01.06.2012
 Drawing - 072-171-003-P3- Michael Punch & Partners dated 01.06.2012
 Report - Michael Punch & Partners July 2009 "Planning Report for Surface Water, Foul Water & Watermain Design"
 Existing drawing information was transcribed from .pdf information and is **approximate in nature** to describe the general principles of the existing drainage layout as indicated in the above drawing and report.

Rev.	Date	Drawn	Description

Do not scale from this Drawing, use figured dimensions only. Check all dimensions on site before commencing work. Report any discrepancies to Architect before proceeding. This Drawing and Designs thereon are copyright of the County Council. ©



Project:	Samuel Beckett Sports Centre										
Title:	Proposed Drainage & Watermain Layout										
SK No:	Code	Originator	Zone	Level	Type	Role	Number	Status	Revision		
D830 - OCSC - XX - XX - SK - S - 0009								S1	P01		
Date:	14/02/2024								By:	EL	