

Proposed New Crematorium and Associated works at Shanganagh Cemetery Shankill, Co Dublin .

Department Reports

Transportation 08/03/2016

Transportation have no objection to your drawing 1785/P/001 dated 23 Feb 2016. They recommend that the number and timing of crematorium services per day is limited and managed to minimise conflict with other uses in the adjoining area.

They suggest that a review of the pedestrian route to the park in vicinity of the recycling vehicle access is undertaken to ensure adequate visibility for exiting vehicles of pedestrians at detailed design stage.

Planning 16/03/2016

Planning have reviewed the revised Part 8 drawings and report and are satisfied that the concerns raised previously have been addressed and have no objection to the proposed development progressing to Part VIII.

Drainage 08/04/2016

Drainage note that the site suitability report submitted by Ian Heffernan and Associates is acceptable as it relates to the area adjacent to the trial hole locations. They note that the location of the Trial Pit are approximately 80.00m from the proposed WWTS and request that if on further investigations during detailed design suitable ground conditions cannot be found adjacent to the preferred site the WWTS shall be relocated towards (adjacent to) the existing trial investigation area.

Housing 18/01/2016

Housing confirmed that they had no objection this development proceeding.