



CLASS 1 BYPASS SEPERATOR NOTES

1. INLET/OUTLET PIPES ARE PLAIN PIPE PVCU. THE STANDARD EN 858 STATES MINIMUM CONNECTION SIZES, UNITS ORDERED WITH DIFFERENT SIZED CONNECTIONS ARE NOT FULLY COMPLIANT WITH THE STANDARD.
2. EXTENSION NECKS FOR DEEPER INVERTS CAN BE PROVIDED. THESE CAN BE CUT IN 200mm SECTIONS. MAX 2.0m INVERT RECOMMENDED.
3. ALL UNITS REQUIRE APPROPRIATE COVER AND FRAME TO SUIT APPLIED LOADINGS.
4. THIS DRAWING SHOULD BE USED FOR DIMENSIONAL INFORMATION ONLY. IT IS ESSENTIAL THAT THIS DRAWING IS READ IN CONJUNCTION WITH THE INSTALLATION GUIDELINES SUPPLIED WITH THE UNIT.
5. A 76mm TUBE (INTERNAL) IS SUPPLIED TO HOUSE AN OIL ALARM PROBE.
6. WET SITE CONDITIONS - CONCRETE BACKFILL
DRY SITE CONDITIONS - PEA SHINGLE BACKFILL